



Richard Harris <rharris@southhadleyma.gov>

North Pole Estates Preliminary Plan - Town of South Hadley - You have a new application for review at 328 HADLEY ST

Scott Brady <sbrady@shfd2.com>
To: Richard Harris <rharris@southhadleyma.gov>
Cc: Todd Calkins <tcalkins@shfd2.com>

Wed, Apr 24, 2019 at 10:12 AM

Richard,

The fire department will require appropriate access to all structures based on our existing and future apparatus as well as a hydrant located every 300 feet with one hydrant located at each entrance.

Best,

Scott

[Quoted text hidden]

[Quoted text hidden]

[Quoted text hidden]

***Only print this e-mail if necessary.**